



County of Siskiyou
Community Development Department
Environmental Health Division/CUPA
Hazardous Materials Management Program
 806 S. Main Street
 Yreka, CA 96097
 (530) 841-2117; Fax (530) 841-4076

Internal Use Only

- UST major repair \$330- Fee Received: \$ _____
 UST minor repair- Fee not required
 Date: _____ Receipt No.: _____
 Approved (see attached conditions if applicable)
 Not Approved
 Issued By: _____ Date: _____
 Expiration Date: _____
 Sisk Co APCD notified Building Dept notified

PERMIT FOR UNDERGROUND STORAGE TANK MODIFICATION/REPAIR

S I T E	Facility Name:	Phone No.:
	Site Address:	
	Owner/Operator:	Phone No.:

C O N T R A C T O R	Contractor Name:	Phone No.:
	Contractor Address:	
	Contractor CA Lic#:	Class:
	Insurer:	Work Comp#:
	ICC Certification Number:	Expiration Date:
	Manufacturer Certification Number:	Expiration Date:

TYPE OF WORK TO BE PERFORMED (select all that apply and attach a detailed scope of work):

<input type="checkbox"/> Piping replacement	<input type="checkbox"/> Piping repair	<input type="checkbox"/> Tank Repair
<input type="checkbox"/> Leak containment sump installation/repair/wall penetration (<input type="checkbox"/> STP sump <input type="checkbox"/> UDC <input type="checkbox"/> Other)		
<input type="checkbox"/> Spill bucket installation	<input type="checkbox"/> Cathodic protection repair/replacement	
<input type="checkbox"/> Overfill alarm installation/repair	<input type="checkbox"/> Replacement of any monitoring equipment with a "non-like" item	
<input type="checkbox"/> Installation of a new monitoring system or console/cold start	<input type="checkbox"/> Other (describe):	

For all equipment listed attach manufacturer's specification sheet

EQUIPMENT TYPE	NAME OF EQUIPMENT MANUFACTURER	MODEL NO.

TERMS OF PERMIT

Applicant Agrees That:

- Siskiyou County Environmental Health (SCEH) will be notified at least 48 hours prior to the start of any work. No work may be performed until this application is approved. Any changes to this approved scope of work must be approved by SCEH.
- Missed appointments or failed inspections may result in a re-inspection fee.
- All UST modifications or repairs must conform to applicable Federal, State, and local statutes and regulations at the time the work is being performed.
- All suspected or confirmed unauthorized releases must be verbally reported to SCEH within 24 hours of discovery and a written report must be submitted within 5 working days per 6.7 HSC 25295. If contamination is detected this permit may be suspended until SCEH determines that the continuation of work will not interfere or inhibit contamination mitigation. Failure to report an unauthorized release will result in immediate work stoppage and may result in permit suspension or revocation and associated fines.
- Prior to permit final, SCEH must receive all required UST system test results and as-built plans. A UST certification of installation/modification form and applicable changes to the UST monitoring plan must be submitted through CERS.

I hereby acknowledge that I have read this application and certify that the information provided on this form and all attached documentation is true, accurate, and complete to the best of my knowledge. If the work authorized under this permit does not begin prior to the permit expiration date an additional permit application and applicable fee will apply.

Applicant Name (Print): _____ Applicant Signature: _____ Date: _____

Permit Final By: _____ Date: _____



COUNTY OF SISKIYOU

COMMUNITY DEVELOPMENT DEPARTMENT
Building ♦ Environmental Health ♦ Planning
806 South Main Street Yreka, California 96097
Phone: (530) 841-2100 · Fax: (530) 841-4076
www.co.siskiyou.ca.us/page/community-development

ALLAN CALDER, AICP
DIRECTOR

UNDERGROUND STORAGE TANK PROGRAM UST PERMIT MODIFICATION/REPAIR GUIDELINES

Work Requiring a Major Modification Permit

Examples of major repairs or modifications include, but are not limited to:

- Piping upgrades
- Piping repairs
- Tank shell repairs
- Sump replacements/repairs
- UDC replacements/repairs
- Cathodic protection replacements

Work Requiring a Minor Modification Permit

Examples of minor repairs or modifications include, but are not limited to (NOTE: extensive repairs listed in this section may be categorized as a major repair at the UST inspector's discretion):

- Spill bucket replacement (not "like for like")
- Overfill alarm installation
- Replacement of any monitoring equipment (not "like for like")
- UST monitor system panel replacement or cold start
- Installation of new conduit into sumps where the wall is penetrated

Work Not Requiring a Permit

The following repairs or modifications do not require a permit from Siskiyou County Environmental Health. However, updated UST tank forms and/or monitoring and response plans are required to be submitted through CERS for any work that affects the status of these forms:

- Replacement of any monitoring equipment that is "like for like"
- Replacement/repairs of spill buckets that are "like for like"
- Replacing/repairing test boots
- Installation of new dispensers (without any work being done below the shear valve)
- Turbine repair/replacement
- Replacing a drop tube
- Electrical repairs/replacement unless it creates new penetrations in sump walls
- UST monitor system panel repairs