



Food Program Official Inspection Report

Siskiyou County Community Development Department
 Environmental Health Division
 806 S. Main Street
 Yreka, California 96097
 phone: (530) 841-2100, fax: (530) 841-4076

Facility Name: Miner Street Station	Permit # 000329
Address: 115 E Miner Street Yreka CA 96097	
Permit Holder: Siskiyou Development	Permit To Operate: <input checked="" type="radio"/> Valid <input type="radio"/> Not Valid
Phone: 530-842-4548 or	E-mail: cindy@sisdevco.com
Food Safety Certified Employee:	Expiration Date:

		MAJ	OUT	COS	
					The marked items represent Health Code violations and must be corrected as follows:
Protection Time/ Temp.	1	Food Temp.			
	2	Prep./ Service			
	3	Storage/ Disp.			
	4	Frozen Food			
	5	Pure Food			
	6	Reused Food			
	7	Transportation			
Food Storage	8	Storage Fac.			
	9	Refrig. Units			
	10	Thermometer			
	11	Hazardous Mat.			
	12	Spoils			
Uten./Equip.	13	Wash/ Sanitize			
	14	Equip. Condition			
	15	Utensil Condition			
	16	Storage			
Employee	17	Handwashing			
	18	Employee Hygiene			
	19	Employee Habits			
	20	Food Cert./ Card		X	
Water	21	Water			
	22	Cross Con.			
Waste	23	Liquid Waste			
	24	Refuse			
Vermin	25	Rodents/ Insects			
	26	Animal/ Fowl			
Facilities	27	Ventilation			
	28	Doors			
	29	Floors		X	
	30	Walls - Ceilings			
	31	Toilet Fac.			
	32	Janitorial Fac.			
	33	Lighting			
Misc.	34	Clothing - Linen			
	35	Signs			
	36	Misc.			

ROUTINE INSPECTION CONDUCTED THIS DATE

20) Obtain Food Manager Certification within the next 60 days.

29) Observed floors in the storage area to have uneven and broken tiles. Flooring in food prep areas need to be cleanable, durable, smooth, and non-absorbent. Repair floors in the storage area and walk-in cooler within the next 90 days.

30) Observed holes in the ceiling of the storage area. Repair ceiling in food storage within the next 90 days.

MAJ = Major violation	OUT = Out of compliance	COS = Corrected on-site
Received By (Print): Edward Ramirez	Received by (Signature):	Date: 11/15/2023
REHS (Print): Alexa Roche	REHS (Signature):	Phone: 530-841-2117

Facility Name: Miner Street Station

The marked items represent Health Code violations and must be corrected as follows:

Received By (Print):
Edward Ramirez

Received by (Signature):

Date:
11/15/2023

REHS (Print):
Alexa Roche

REHS (Signature):

Phone:
530-841-2117

Facility Name: Miner Street Station

The marked items represent Health Code violations and must be corrected as follows:

Received By (Print): Edward Ramirez Received by (Signature): Date: 11/15/2023

REHS (Print): Alexa Roche REHS (Signature): Phone: 530-841-2117

Facility Name: Miner Street Station

The marked items represent Health Code violations and must be corrected as follows:

Received By (Print):
Edward Ramirez

Received by (Signature):

Date:
11/15/2023

REHS (Print):
Alexa Roche

REHS (Signature):

Phone:
530-841-2117